



**Drinking Water Quality and Compliance  
for The Village of Muenster  
2025 Annual Notice to Consumers**

**Introduction**

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Village of Muenster's water quality and sample submission compliance records for the January 1, 2025 to December 31, 2025 time period. This report was completed on February 4, 2025 (*must be completed before June 30 each year on a calendar year based reporting frequency*). Readers should refer to Saskatchewan Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of selenium in a water supply", more detailed information is available from:

[http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html)

**Water Quality Standards**

**Bacteriological Quality**

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and	0 Organisms/100 mL	52	52	0
E. coli	0 Organisms/100 mL	52	52	0
Background Bacteria	Less than 200/100 mL			

*The owner/operator is responsible to ensure that 100 per cent of all bacteriological samples are submitted as required. All waterworks are required to submit samples for bacteriological water quality, the frequency of monitoring depends on the population served by the waterworks.*

**Water Disinfection –**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.51-1.07	0.37 - 0.87	52	52	100%

*A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual OR 0.5 mg/L total chlorine residual is required at all times throughout the distribution system unless otherwise approved. A proper chlorine submission is defined as a bacteriological sample submission form with both the free and total chlorine residual fields filled out. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. An adequate chlorine may be counted even if the chlorine results were submitted incorrectly. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.*

**Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.40-0.88	365	0

*A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.*

**Turbidity – From Water Treatment Plant Records**

Parameter	Limit	Test Level # Tests	# Tests Not Meeting Requirements	Maximum	# Tests	# Tests
	(NTU)	Range		Turbidity (NTU)	Required	Performed
Turbidity	1.0	0.02- 0.16	0	0.16	365	365

*Turbidity is a measure of water treatment efficiency. Turbidity measures the "clarity" of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU). All waterworks are required to monitor turbidity at the water treatment plant. The frequency of measurement varies from daily for small systems to continuous for larger waterworks.*

**Chemical – Halo Acetic Acids (HAAs)**

Parameter	HAAs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Halo Acetic Acids	0.080	0.0443	4 (1 every 3 months)	4

**Chemical – Trihalomethanes (THMs)**

Parameter	THMs Limit (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes	0.1	0.0454	4 (1 every 3 months)	3

*THMs and Haloacetic Acids are generated during the water disinfection process as a by-product of reactions between chlorine and organic material. THMs are generally found only in drinking water obtained from surface water supplies. THMs and HAAs are to be monitored on a quarterly basis and the IMAC result is expressed as an average of 4 quarterly samples. Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs and Haloacetic Acids unless otherwise specified in the facility Permit to Operate.*

**More information on water quality and sample submission performance may be obtained from:**

Village of Muenster  
Box 98  
Muenster, Saskatchewan  
S0K 2Y0  
PH: 306-682-2794  
Email: muenster@sasktel.net

**ANNUAL FINANCIAL OVERVIEW (2025)**

\*Pre-Audit Overview – Village of Muenster

Total 2025 waterworks operating revenues (R) - \$236,627

Total 2025 waterworks operating expenditures (E) - \$275,494

Total debt payments of waterworks infrastructure loans (D) – \$51,124

Comparison of waterworks operating revenues to operating expenditures plus debt payments,

expressed as a ratio –  $\frac{(\$236,627)}{(\$275,494) + (51,124)}$  = .72

For 2025, waterworks operating revenues covered 72 percent of the waterworks operating expenditures.

\*Total 2025 waterworks expenditures of \$275,494 includes an amortization figure of \$47,970.)

\*Also to note, Water Treatment Plant Reservoir Debenture fully paid off in 2025. \$34,198

\*Also to note, Sewer Lift Station Debenture fully paid off in 2025. \$16,925

**RESERVES**

Dec 31, 2025 Reserves available for waterworks capital infrastructure:

Capital Trust Fund - \$241,879

Utility Reserve Fund - \$13,673

Waterworks Information available for review at the Village of Muenster Office:

- Waterworks Rate Policy and Capital Investment Strategy
- Financial Overview of the Waterworks
- Reserves available for Waterworks Projects
- Copy of the 2023 Capital Asset Assessment